

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001

No.F.6 DFS/MS/School/2023/SZ/ 126

Dated: 23 / 02 / 2023

FIRE SAFETY CERTIFICATE

Certified that the **Mount Columbus School** located at C-Block, Dakshinpuri, New Delhi 110062 Comprised of Two Blocks- Senior Block (Ground plus two upper floors) & Junior Block- (Small Basement, Ground plus one upper floor) owned/occupied by Mount Columbus School was issued Fire Safety Certificate by this department vide letter no. F6/DFS/MS/School/2017/SZ/1129 Dt. 28/07/2017. The said premises was re-inspected by officer concerned of this department on 18/02/2023 in presence of Sh. Rakesh Kumar and found that the said school building have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules 2010 and that the building is fit for occupancy class "**Educational Building Group - B**" with effect from 23/02/2023 for a period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of Delhi Fire Service Rules 2010.

Issued on 23/02/2023 at New Delhi by



(SUNIL CHAWDHARY)
CHIEF FIRE OFFICER
DELHI FIRE SERVICE

Copy to: -

1. The Principal, Mount Columbus School at C-Block, Dakshinpuri, New Delhi 110062
2. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi- 54.

Conditions for the validity of Fire Safety Certificate:-

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. The basement shall be used as per the provisions of BBL /NBC Part- IV.
4. All the staff members must know the correct method of operation of firefighting system.
5. The owner/ occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
6. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
7. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry."


Principal
Mount Columbus School
C-Block, Dakshinpuri
New Delhi-110062